

Genesee Intermediate School District

SES North Construction RFP

Addendum Number 1 dated 3/3/2023

This Addendum addresses vendor questions received during the recommended pre-bid meeting on March 3, 2023. NOTE: The bid date for this Request for Proposals remains unchanged, March 15, 2023 at 2:00 PM. All other terms and conditions of the bid shall remain in full force and effect.

1. Document Updates
 - a. Attachment A2 (Map) and A3 (Reference) are included with this addendum.
2. Attachment E – is there a spot for the signature and notary?
 - a. Attachment E requires a signature but does not need to be notarized, please see updated form with signature line.
3. What type and count of fiber do you need (Section 3, Item B)
 - a. 12 count multi-mode fiber
 - b. SC Connectors on the panel
4. Section 3, Item H – Apple TVs
 - a. GISD will provide the Apple TVs for this project. Vendor will just need to have a spot to connect them into the AV System and program them as an input.
5. Update on Directors Office (Room 117)
 - a. There will be a second HDMI connection under the TV (18”) that runs up behind the TV.
6. Update on Collaboration Rooms (Rooms 118 and 119)
 - a. There will be a single HDMI connection under the TV (18”) that runs up behind the TV. There will not be an HDMI connection from the director’s office to these rooms.
7. Do we need a lift for this project?
 - a. Up to the vendor. The ceiling in the main conference center (Room 113 and 114) is 11’.
 - b. The ceiling in the construction area is all drop ceiling.
8. Installation
 - a. Wireless – Please include a cost to install the 6 access points. GISD will handle configuration of the devices.
 - b. Security Cameras – Please include cost to mount, install, and aim seven (7) security cameras (4 external, 3 internal).
9. Take note – item R16 – There is a CAT6 connection to a parking lot light pole to support a video camera. The camera will be approximately 10-12’ up the pole.